

A NOTICE TO PARENTS, GUARDIANS, and STAFF

Cornwall Elementary School at Lee Road

Lead Testing of School Drinking Water

(March 1, 2024)

Safe and healthy school environments can foster healthy and successful children. To protect public health, the Public Health Law and New York State Health Department (NYSDOH) regulations require that all public schools and boards of cooperative educational services (BOCES) test lead levels in water from every outlet that is used, or could potentially be used, for drinking or cooking. Revisions effective March 22, 2022, reduce the lead action level in drinking water from 15 parts per billion (ppb) to 5 ppb. If lead is found at any water outlet at levels above 5 parts per billion (ppb)¹, which is equal to 5 micrograms per liter (µg/L), the NYSDOH requires that the school take action to reduce the exposure to lead.

Rule of Thumb²

- *Any outlet in a room or office within a school not used by students (pre-kindergarten through grade 12), for drinking or cooking, does not require sampling. An example is custodial storage closet dispensing cleaning chemicals*
- **Lavatory Sinks:** Toilet rooms and bathrooms are building environments that can present unique challenges to water portability. These challenges are reflected in various code provisions that prohibit the installation of drinking facilities, drinking fountains, water coolers, and water dispensers within toilet rooms and bathrooms. NYS DOH would not object to designating these outlets as not applicable where controls (e.g., education and signage) exist to prevent the consumption of water. "Handwashing Only, Not for Drinking" signs have been posted
- **Dishwashing outlets:** If an outlet is designated for dishwashing only and involves no opportunity for drinking or cooking including food preparation, the outlet does not require sampling.
- **Science/Art sinks:** *Classrooms in these settings prohibit eating and/or drinking. The sinks within these rooms are not for drinking or cooking.* "Handwashing Only, Not for Drinking" signs have been posted.
- **Classroom sinks:** If the outlet is used for drinking and/or cooking, it must be sampled. However, if the school has controls in place to prevent the consumption of water, Superintendents or their designees have the discretion to exclude these outlets from sampling and include them in the Remedial Action Plan.

What is first draw testing of school drinking water for lead?

The "on-again, off-again" nature of water use at most schools can raise lead levels in school drinking water. Water that remains in pipes overnight, over a weekend, or over vacation periods stays in contact with lead pipes or lead solder and, as a result, could contain higher levels of lead. This is why schools are required to collect a sample after the water has been sitting in the plumbing system for a certain period of time. This "first draw" sample is likely to show higher levels of lead for that outlet than what you would see if you sampled after using the water continuously. However, even if the first draw sample does not reflect what you would see with continuous usage, it is still important because it can identify outlets that have elevated lead levels.

What are the results of the first draw testing?

<i>Location</i>	<i>Sampling Dates</i>	<i>Results PPB</i>	<i>Summary of Results</i>
<i>Kitchen Sink #1 Island Prep Sink</i>	<i>2/21/2024</i>	None Detected	
<i>Kitchen Sprayer</i>	<i>2/21/2024</i>	None Detected	
<i>Kitchen Pot Filler</i>	<i>2/21/2024</i>	3.2	
<i>Bottle Filler: Cafeteria</i>	<i>2/21/2024</i>	None Detected	<i>Filter: None Detected</i>
<i>Drinking Fountain: Cafeteria</i>	<i>2/21/2024</i>	None Detected	<i>Filter: None Detected</i>
<i>Nurse's Office Sink</i>	<i>2/21/2024</i>	None Detected	
<i>Bottle Filler: M18/Gym</i>	<i>2/21/2024</i>	None Detected	<i>Filter: None Detected</i>
<i>Drinking Fountain: M18/Gym</i>	<i>2/21/2024</i>	None Detected	<i>Filter: None Detected</i>
<i>Bottle Filler by Room 208 #1 - Left</i>	<i>2/21/2024</i>	None Detected	<i>Filter: None Detected</i>
<i>Drinking Fountain by Room 208 #1 - Left</i>	<i>2/21/2024</i>	None Detected	<i>Filter: None Detected</i>
<i>Bottle Filler by Room 208 #2 - Center</i>	<i>Not in Service</i>	<i>TBA</i>	
<i>Fountain by Room 208 #2- Center</i>	<i>Not in Service</i>	<i>TBA</i>	

¹ Action Level lowered from 15 ppb to 5 ppb. Revisions to the Public Health Law (PHL) Section 1110 went into effect on December 22, 2022

² *New York State Department of Health Lead Testing in School Drinking Water Program Guidance Manual; November 6, 2023*

Bottle Filler by Room 208 #3- Right	2/21/2024	None Detected	Filter: None Detected
Drinking Fountain by Room 208 #3- Right	2/21/2024	None Detected	Filter: None Detected
Bottle Filler by Room 108 #1 - Left	2/21/2024		Filter: None Detected
Drinking Fountain by Room 108 #1 - Left	2/21/2024		Filter: None Detected
Bottle Filler Room 108 #2 - Center	2/21/2024	None Detected	Filter: None Detected
Fountain by Room 108 #2- Center	2/21/2024	None Detected	Filter: None Detected
Bottle Filler by Room 108 #3- Right	2/21/2024	None Detected	Filter: None Detected
Drinking Fountain by Room 108 #3- Right	2/21/2024	None Detected	Filter: None Detected
Room K1 Classroom Sink	2/21/2024	None Detected	
Room K1 Bubblers	Not in Service	TBA	
Room K2 Classroom Sink	2/21/2024	None Detected	
Room K2 Bubblers	Not in Service	TBA	
Room K3 Classroom Sink	2/21/2024	None Detected	
Room K3 Bubblers	Not in Service	TBA	
Room 108 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 109 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 111 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 113 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 114 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 115 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 116 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Bottle Filler by Room M10/Cafe-#1 Left	2/21/2024	None Detected	Filter: None Detected
Fountain by Room M10/Cafe - #1 Left	2/21/2024	None Detected	Filter: None Detected
Bottle Filler by Room M10/Cafe#2 Right	2/21/2024	None Detected	Filter: None Detected
Fountain: by Room M10/Cafe-#2 Right	2/21/2024	None Detected	Filter: None Detected
Main Office Bottle Filler	2/21/2024	None Detected	
Main Office Fountain	2/21/2024	None Detected	
Room 101 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 102 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 103 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 105 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 106 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 110 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 202 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 203 Classroom Sink	2/21/2024	2.0	Replaced 2023
Room 204 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 205 Classroom Sink	2/21/2024	1.1	(Replaced 2023): Resampled 3/22/2024
Room 206 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 208 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 209 Classroom Sink	2/21/2024	1.4	Replaced 2023
Room 210 Classroom Sink	2/21/2024	1.5	Replaced 2023
Room 211 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 213 Classroom Sink	2/21/2024	1.3	Replaced 2023
Room 214 Classroom Sink	2/21/2024	1.0	Replaced 2023
Room 215 Classroom Sink	2/21/2024	None Detected	Replaced 2023
Room 216 Classroom Sink	2/21/2024	1.3	Replaced 2023
"Non-applicable outlets"			
Kitchen Sink #2 (Dishwashing Sink #1)	Dishwashing outlet	Posted	Posted: Do Not Drink; Hand wash Only
Kitchen Sink #3 (Dishwashing Sink #2)	Dishwashing outlet	Posted	Posted: Do Not Drink; Hand wash Only
Kitchen Handwashing Sink	Hand wash Only	Posted	Hand Washing Only
Nurse's Office Bathroom Sink	Lavatory Sinks	Posted	Posted: Do Not Drink; Hand wash Only
Room K1 Bathroom Sink	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room K2 Bathroom Sink	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room K3 Bathroom Sink	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Faculty Bathroom outside K3	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Girls 1st Floor(100's) Gang Bathroom Sink #1	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Girls First Floor Gang Bathroom Sink #2	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Girls First Floor Gang Bathroom Sink #3	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Boys First Floor Gang Bathroom Sink #1	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only

Boys First Floor Gang Bathroom Sink #2	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Boys First Floor Gang Bathroom Sink #3	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room 201 Right Side Classroom Sink	Science/Art sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room 201 Left Front Sink #1	Science/Art sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room 201 Left Front Sink #2	Science/Art sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room 201 Left Front Sink #3	Science/Art sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room 201 Left Back Sink #1	Science/Art sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room 201 Left Back Sink #2	Science/Art sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room 201 Left Back Sink #3	Science/Art sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Girls 2 nd Floor (200's) Gang Bathroom Sink #1	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Girls Second Floor Gang Bathroom Sink #2	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Girls Second Floor Gang Bathroom Sink #3	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Girls Second Floor Gang Bathroom Sink #4	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Boys Second Floor Gang Bathroom Sink #1	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Boys Second Floor Gang Bathroom Sink #2	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Boys Second Floor Gang Bathroom Sink #3	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Boys Second Floor Gang Bathroom Sink #4	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room M-15 Classroom Sink	Hand wash Only	Posted	Hand Washing Only
Room M-22 Storage Bath Sink	Lavatory Sinks	Posted	Posted: Do Not Drink; Hand wash Only
Accessibility Bathroom Sink (outside M16)	Lavatory Sinks	Posted	Posted: Do Not Drink; Hand wash Only
Woman Faculty Bathroom Sink (outside M18)	Lavatory Sinks	Posted	Posted: Do Not Drink; Hand wash Only
Library Office Sink	Hand wash Only	Posted	Hand Washing Only
Room M20: PE Coach Office Bathroom Sink	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Room M19 Bathroom Sink (gymnasium)	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Girls' Bathroom Sink Café/kitchen entrance	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Boys' Bathroom Sink Café/kitchen entrance	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Custodial Office Bathroom Sink	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Custodial Women Bathroom Sink	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Women's Faculty Bath Sink near Main Office	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only
Men's Faculty Bath Sink Outside Main Office	Lavatory Sinks	Replaced 2023	Posted: Do Not Drink; Hand wash Only

What is being done in response to the results?

Outlets that tested with lead levels above the action level (15 ppb) were removed from service, unless an outlet is a sink faucet needed for handwashing. In that case, a sign was posted at the outlet indicating that the sink is not to be used for drinking. Outlets that tested below the action level remain in service with no restrictions.

Location	Immediate Action	Remediation
Room K1 Bubblers	Not in Service	Test once repaired
Room K2 Bubblers	Not in Service	Test once repaired
Room K3 Bubblers	Not in Service	Test once repaired
Bottle Filler by Room 208 #2 - Center	Not in Service	Test once repaired
Fountain by Room 208 #2- Center	Not in Service	Test once repaired

Water Fountain and sink faucets requiring replacement, as part of the remediation plan will be retested after installation; all other locations will follow the Department of Health guidelines and are scheduled for retesting in the year 2027.



What are the health effects of lead?

Lead is a metal that can harm children and adults when it gets into their bodies. Lead is a known neurotoxin, particularly harmful to the developing brain and nervous system of children under 6 years old. Lead can harm a young child's growth, behavior, and ability to learn. Lead exposure during pregnancy may contribute to low birth weight and developmental delays in infants. There are many sources of lead exposure in the environment, and it is important to reduce all lead exposures as much as possible. Water testing helps identify and correct possible sources of lead that contribute to exposure from drinking water.

What are the other sources of lead exposure?

Lead is a metal that has been used for centuries for many purposes, resulting in widespread distribution in the environment. Major sources of lead exposure include lead-based paint in older housing, and lead that built up over decades in soil and dust due to historical use of lead in gasoline, paint, and manufacturing. Lead can also be found in a number of consumer products, including certain types of pottery, pewter, brass fixtures, foods, plumbing materials, and cosmetics. Lead seldom occurs naturally in water supplies but drinking water could become a possible source of lead exposure if the building's plumbing contains lead. The primary source of lead exposure for most children with elevated blood-lead levels is lead-based paint.

Should your child be tested for lead?

The risk to an individual child from past exposure to elevated lead in drinking water depends on many factors; for example, a child's age, weight, amount of water consumed, and the amount of lead in the water. Children may also be exposed to other significant sources of lead including paint, soil and dust. Since blood lead testing is the only way to determine a child's blood lead level, parents should discuss their child's health history with their child's physician to determine if blood lead testing is appropriate. Pregnant women or women of childbearing age should also consider discussing this matter with their physician.

Additional Resources

For more information regarding the testing program or sampling results, contact John Pinckney at (845)534-8009, ext. 5228, or go to our school website: www.cornwallschools.com

For information about lead in school drinking water, go to:

http://www.health.ny.gov/environmental/water/drinking/lead/lead_testing_of_school_drinking_water.htm

<http://www.p12.nysed.gov/facplan/LeadTestinginSchoolDrinkingWater.html>

For information about NYS Department of Health Lead Poisoning Prevention, go to: <http://www.health.ny.gov/environmental/lead/>

For more information on blood lead testing and ways to reduce your child's risk of exposure to lead, see "What Your Child's Blood Lead Test Means": <http://www.health.ny.gov/publications/2526/> (available in ten languages).